



- NOTES:**
1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL RELEVANT ENGINEER'S AND ARCHITECT'S DRAWINGS AND SPECIFICATIONS
 2. ALL LEVELS ARE IN METRES TO ORDNANCE DATUM, MALIN HEAD.
 3. POSITION OF EXISTING WATERMAIN TO BE CONFIRMED PRIOR TO LAYING OF NEW WATERMAIN.
 4. ALL SERVICE PIPES TO M&E SPEC AND DETAIL CONNECTED TO WATERMAIN IN ACCORDANCE WITH IRISH WATER REQUIREMENTS.
 5. ALL WATERMANS AND ASSOCIATED FITTINGS TO BE CONSTRUCTED IN ACCORDANCE WITH IRISH WATER PUBLICATION "WATER INFRASTRUCTURE STANDARD DETAILS, DOCUMENT NUMBER: IW-GDS-5020-01 AND "CODE OF PRACTICE FOR WATER INFRASTRUCTURE" DOCUMENT NUMBER IW-GDS-5020-03
 6. NEW WATERMANS ARE TO BE INSTALLED WITH A MINIMUM COVER OF 900mm IN ACCORDANCE WITH THE IRISH WATER DETAIL STD-W-013 (SEE NOTE 5.)
 7. ALL SLUICE VALVE AND HYDRANT CHAMBERS ARE TO BE CONSTRUCTED FROM BLOCKWORK
 8. ALL MARKER POST AND PLATES ARE TO BE IN ACCORDANCE WITH IRISH WATER DETAIL STD-W-27 (SEE NOTE 5.)
 9. ALL THRUST BLOCKS ARE TO BE IN ACCORDANCE WITH IRISH WATER DETAIL STD-W-28 (SEE NOTE 5.)
 10. ALL SLUICE VALES TO BE IN ACCORDANCE WITH THE REQUIREMENTS CALLED UP ON IRISH WATER DETAIL STD-W-15 (SEE NOTE 5.)
 11. ALL HYDRANT TO BE IN ACCORDANCE WITH THE REQUIREMENTS CALLED UP ON IRISH WATER DETAIL STD-W-18 (SEE NOTE 5.)
 12. ALL WATER METER ACCESS POINTS REQUIRE MARKER POST & PLATES TO STD-W-27-REV2 TYPICAL.

- LEGEND:**
- EXISTING BUILDING
 - PROPOSED BUILDING
 - LANDSCAPE (REFER TO ARCHITECT'S DRAWINGS FOR DETAILS)
 - PROPOSED ROAD
 - PROPOSED PAVEMENT
 - GRASSCRETE PAVING
 - EXISTING WATERMAIN
 - EXISTING HYDRANT
 - EXISTING SLUICE VALVE
 - EXISTING AIR VALVE
 - PROPOSED WATERMAIN
 - PROPOSED HYDRANT
 - PROPOSED SLUICE VALVE
 - SITE BOUNDARY
 - PROPOSED FINISH FLOOR LEVEL

No.	Revision	Date	By	CHK'd	App'd
P04	ISSUE FOR INFORMATION	17.04.23	GH	SK	KOR
P03	ISSUE FOR INFORMATION	05.01.23	LW	SK	KOR
P02	ISSUE FOR INFORMATION	14.12.22	LW	SK	KOR
P01	ISSUE FOR INFORMATION	11.11.22	RE	SK	KOR

FOR PLANNING APPROVAL

PROJ ROD Offices: Dublin - Sandycroft & Santry
Leeds - Otley
Ireland 1+353 (0) 1 294 0800
UK 1+44 (0) 113 360 1720

Client: **FINGAL COUNTY COUNCIL**

Project Title: **BALDOYLE COMMUNITY CENTRE**

Drawing Title: **PROPOSED WATERMAIN LAYOUT**

Drawing Number	BCC-ROD-00-XX-DR-C-0041	Rev	P04
Scale:	1:250 @A1	Date:	NOV 22
Drawn:	RE	Checked:	SK
Approved:	KOR	Project No:	21.115.101
Status Code:	S2 - SUITABLE FOR INFORMATION		

DO NOT SCALE USE FIGURED DIMENSIONS ONLY