



Betania Church

Powerstown Educate Together National School

TYPE A COLUMN DETAILS

HEIGHT : 6m
 INCLINATION : 5 Degrees
 COLUMN QUANTITY : 94
 LANTERN DETAILS : 94
 MAKE & MODEL : CUJ Phosco PHS2-1243MW-CAD69

TYPE B COLUMN DETAILS

HEIGHT : 5m
 INCLINATION : 0 Degrees
 COLUMN QUANTITY : 5
 LANTERN DETAILS : 5
 MAKE & MODEL : CUJ Phosco PHS2-1243MW-CAD000

Notes:
 All LED luminaires must have Constant Light Output (CLO).
 All luminaires to have 7 year minimum warranty.
 Electronic ballasts to be used at 50% duty.
 Minimum 50% dimming for public lighting.
 No trees to be located within falling distance of the columns.
 Minimum spacing of columns to be determined based on site.



NOTES

THE DRAWING IS THE INTELLECTUAL PROPERTY OF SABRE ELECTRICAL SERVICES LTD. AND IS COPYRIGHTED. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING FROM SABRE ELECTRICAL SERVICES LTD.

NO ACCOUNT IS TAKEN FOR THE BECOMING EFFECT CAUSED BY BUILDINGS, TREES, ETC. THE CLIENT MUST BE AWARE THAT THE DRAWING ASSUMES THAT THE FINAL LAMP HEIGHT AND POSITION WILL BE AS SHOWN. THE CLIENT MUST BE AWARE THAT THE FINAL LAMP HEIGHT AND POSITION WILL BE AS SHOWN.

Ready to install. Any alterations to the layout of luminaires must be agreed with Sabre Electrical Services Ltd. before installation. Any alterations to the layout of luminaires must be agreed with Sabre Electrical Services Ltd. before installation.



ELECTRICAL SERVICES LTD.
 Specialist Contractors
 PUBLIC LIGHTING - FLOOD LIGHTING - SPORTS LIGHTING

UNIT 11,
 BELLVALE INDUSTRIAL ESTATE,
 FINGLAS,
 DUBLIN 11.
 E-MAIL: graham@sabrelighting.ie PH: 01-811 0875

CLIENTS/TOWER

Waterman Moylan
 Part XI Churchfields and Eastern Linear Park Development
 Public Lighting ISOLUX

REV./DESCRIPTION	DATE	INTS	CHNG	DATE
1	20-10-21			

PROJECT NUMBER	SES 75521	ISSUE	1
DRAWING NUMBER	SES 75521	ISSUE	1
DRAWN	GS	DATE	20-10-21
SCALE	1:7500@A1		
DATE	20-10-21		

DO NOT SCALE FROM THIS DRAWING