



Betania Church

Powerstown Educate Together National School

Note:
All LED luminaire must have Constant Light Output (CLO).
All luminaire must be fully adjustable or dimmable to allow
Adjustment to meet 'E' & 'B' values under test.
Electronic Prolonged switched at 20/18h.
All luminaire, luminaire, cable and other, shall comply with local Authority
Requirements.
All luminaire to have the same 'Shaded Light' as specified.
Minimum height of luminaire to be 500mm from level of beam.
Minimum height of luminaire to be 500mm from level of beam.
Authority of Local Authority.
Authority of Local Authority.

TYPE A COLUMN DETAILS

HEIGHT	6m
INCLINATION	5 Degrees
COLUMN QUANTITY	94
LANTERN DETAILS	CUJ Photo PISO-124RBM-CM099
MAKE & MODEL	CUJ Photo PISO-124RBM-CM099

TYPE B COLUMN DETAILS

HEIGHT	5m
INCLINATION	0 Degrees
LANTERN DETAILS	CUJ Photo PISO-124RBM-CM099
MAKE & MODEL	CUJ Photo PISO-124RBM-CM099

Typical Base detail to be checked
by site engineers.

ITEM	DESCRIPTION	UNIT	QTY	UNIT PRICE	TOTAL
A	Column Mounting Height	12m	1.7m	1.5m	1.0m
B	Cable Entry Depth	0.2m	0.2m	0.2m	0.2m
C	Column Concrete Depth	1.5m	1.5m	1.5m	1.5m
D	Column Footing Depth	1.5m	1.5m	1.5m	1.5m
E	Column Slab Height	1.5m	1.5m	1.5m	1.5m
F	Excavation Depth	1.5m	1.5m	1.5m	1.5m

NOTES

1. THE DRAWING IS THE INTELLECTUAL PROPERTY OF SABRE ELECTRICAL SERVICES LTD. AND IS CONFIDENTIAL. IT IS NOT TO BE REPRODUCED OR COPIED IN ANY FORM OR BY ANY MEANS WITHOUT THE WRITTEN PERMISSION OF SABRE ELECTRICAL SERVICES LTD.

2. THE CLIENT HAS AGREED TO THE DRAWING ASSUMING THAT THE FINISH LAMP AND ELEVATION IS AS SHOWN.

3. THE DRAWING IS BASED ON THE INFORMATION PROVIDED BY THE CLIENT. SABRE ELECTRICAL SERVICES LTD. ACCEPTS NO LIABILITY FOR ANY ERRORS OR OMISSIONS IN THE DRAWING.

4. ANY CHANGES TO THE DRAWING MUST BE APPROVED BY SABRE ELECTRICAL SERVICES LTD. AND THE CLIENT.

SABRE ELECTRICAL SERVICES LTD.
Specialist Contractors
PUBLIC LIGHTING · FLOOD LIGHTING · SPORTS LIGHTING

UNIT 11, BELVUE INDUSTRIAL ESTATE, FINGLAS, DUBLIN 11. E-MAIL: graham@sabrelighting.ie PH: 01-811 0875

CLIENT/CUSTOMER
Waterman Moylan
Project Part XI Churchfields and Eastern Linear Park Development

TITLE
Public Lighting Layout

DRAWN	SCALE	DATE
G.S.	1:750@A1	26-10-21
DRAWING NUMBER	ISSUE	
SES 15521	1	

DATE DRAWING NUMBER 06th
DRAWING NUMBER 06th

DO NOT SCALE FROM THIS DRAWING

